

TRIBAL SUND  
TRUST  
Imp: 6/6/07

# Indian Country Data Needed During an UST Inspection

SPOKE TO: Carel Cox, PHONE #: 712/423-3979

Number of Tanks 6 - 3x10,000 (GAS) 3x18000 (Diesel)

DATE OF LAST INSPECTION: 6/25/04

FACILITY: Fuel PLAZA, 17223 W. 210th St. ONAWA, IA

LONGITUDE: W94°12.5828' LATITUDE: N42° 3.3106'

2004 Discrepancy: Failure to provide release detection for piping  
Piping equipped w/an automatic line leak detector  
must have an annual line tightness test.

SOC:

SOC	
Unknown	
Does not Meet both regulations	
Does not meet release detection requirements	X
Does not meet release prevention requirements	
In SOC	

PIPING MATERIAL (CHOOSE ONE)	
Bare steel	
Cooper	
Galvanized steel	
Flexible reinforced plastic	
Flexible plastic	✓
No piping	
Not listed	
ORNI FLEX Other	

TANK MATERIAL (CHOOSE ONE)	
Asphalt coated or bare steel	
Epoxy coated steel	
Cathodically protected steel	
Fiberglass reinforced plastic	DWL
Composite (steel w/FRP concrete)	
Polyethylene tank jacket	
Not listed	
Other	
Unknown	

SEC PIPING OPTIONS	
Doubled walled	✓
Cathodically protected	
Secondary containment	
Non-corroding secondary containment	
None	

TYPE OF PIPING OPTIONS	
Gravity Feed	
Pressurized	✓
Safe suction	
US Suction	
Not listed	

Has piping been repaired N  
Does tank use emergency generator N  
Has piping been repaired N

Financial  
Responsibility: ND

### CHOOSE THE APPROPRIATE BOX

RELEASE DETECTION	TANK	PIPE
Manual tank gauging		
Tank tightness testing		
Inventory control		
Automatic tank gauge	✓	
Vapor monitoring		
Groundwater monitoring		
SIR		
Interstit Dbl-wall monitor		
Interstit. Sec. Con. Monitor		
Auto line leak detector		
Line tightness testing		
Other method		
Deferred		
Not listed		
Sump Sensor		

CORROSION PROTECTION	TANK	PIPE
FRP	X	X
Impressed Current		
Sacrificial Anodes		
Interior Lining		

SPILL OVERFILL PROTECTION	
Spill over fill protection	✓
Spill protection	✓

ATG MANUFACTURER	
2000 <del>2000</del> EECO	✓
Galbarco	
Image II	
Incon	
Petro Vend	
Prolink	
Red	
Veeter-Rooter	

MTG Model \_\_\_\_\_

SIR VEND \_\_\_\_\_

Check if deliveries limit is 25 gallons or less \_\_\_\_\_